

City of Fitchburg
2023 PFAS Test Results

PFAS Compound		DHS Recommendations		Well 4 ng/l	Well 5 ng/l	*Well 7 ng/l	*Well 8 ng/l	Well 10 ng/l	Well 11 ng/l
		Preventative Limit ng/l	Enforcement Standard ng/l						
Perfluorotridecanoic acid	PFTriA	DNR	DNR	nd	nd	nd	nd	nd	nd
Perfluorododecanoic acid	PFDoA	100	500	nd	nd	nd	nd	nd	nd
Perfluoroundecanoic acid	PFUnA	600	3,000	nd	nd	nd	nd	nd	nd
Perfluorodecanoic acid	PFDA	60	300	nd	nd	nd	nd	nd	nd
Perfluorononanoic acid	PFNA	3	30	nd	nd	nd	nd	nd	nd
Perfluorooctanoic acid	PFOA	2	20	nd	nd	nd	nd	nd	nd
Perfluoroheptanoic acid	PFHpA	DNR	DNR	nd	nd	nd	nd	nd	nd
Perfluorohexanoic acid	PFHxA	30,000	150,000	nd	nd	0.148	nd	nd	nd
Perfluoropentanoic acid	PFPeA	DNR	DNR	nd	nd	nd	nd	nd	nd
Perfluorobutanoic acid	PFBA	2,000	10,000	nd	nd	nd	nd	nd	nd
Perfluorotetradecanoic acid	PFTeA	2,000	10,000	nd	nd	nd	nd	nd	nd
Perfluorodecanesulfonic acid	PFDS	DNR	DNR	nd	nd	nd	nd	nd	nd
Perfluorononanesulfonic acid	PFNS	DNR	DNR	nd	nd	nd	nd	nd	nd
Perfluorooctanesulfonic acid	PFOS	2	20	nd	nd	0.139	nd	nd	nd
Perfluoroheptanesulfonic acid	PFHpS	DNR	DNR	nd	nd	nd	nd	nd	nd
Perfluorohexanesulfonic acid	PFHxS	4	40	nd	nd	0.15	0.273	nd	nd
Perfluoropentanesulfonic acid	PFPeS	DNR	DNR	nd	nd	nd	nd	nd	nd
9-chlorohexadecafluoro-3-oxanonane-1-sulfonic acid	9-Cl	DNR	DNR	nd	nd	nd	nd	nd	nd
11-chloroeicosafuoro-3-oxaundecane-1-sulfonic acid	11-Cl	DNR	DNR	nd	nd	nd	nd	nd	nd
Perfluorobutanesulfonic acid	PFBS	90,000	450,000	nd	nd	nd	0.293	nd	nd
Perfluorooctanesulfonamide	PFOSA	2	20	nd	nd	nd	nd	nd	nd
8:2 fluorotelomer sulfonic acid	FtS 8:2	DNR	DNR	nd	nd	nd	nd	nd	nd
6:2 fluorotelomer sulfonic acid	FtS 6:2	DNR	DNR	nd	nd	nd	nd	nd	nd
4:2 Fluorotelomer sulfonic acid	FtS 4:2	DNR	DNR	nd	nd	nd	nd	nd	nd
2-(N-Methylperfluorooctanesulfonamido) acetic acid	NMeFOSAA	DNR	DNR	nd	nd	nd	nd	nd	nd
Perfluoro-2-methyl-3-oxahexanoic acid	HFPO-DA (GenX)	30	300	nd	nd	nd	nd	nd	nd
4,8-Dioxa-3H-perfluorononanoic acid	ADONA	600	3,000	nd	nd	nd	nd	nd	nd
2-(N-Ethylperfluorooctanesulfonamido) acetic acid	NEtFOSAA	2	20	nd	nd	nd	nd	nd	nd
Perfluoro-3,6-dioxaheptanoic acid	NFDHA	60	300	nd	nd	nd	nd	nd	nd
Perfluoro(2-ethoxyethane)sulfonic acid	PFEESA	DNR	DNR	nd	nd	nd	nd	nd	nd
Perfluoro-4-methoxybutanoic acid	PFMBA	DNR	DNR	nd	nd	nd	nd	nd	nd
Perfluoro-3-methoxypropanoic Acid	PFMPA	DNR	DNR	nd	nd	nd	nd	nd	nd

nd: No Detect

DNR: WI Department of Health Services (DHS) does not have a recommendation at this time.

*Well 7 and Well 8 data from 2021